



# Certificate of Compliance

**Certificate:** 2474731 (LR 43674)

**Master Contract:** 157607

**Project:** 2474731

**Date Issued:** September 28, 2012

**Issued to:** Intertec Instrumentation Ltd

255 Henry Dr  
Sarnia, ON N7T 7H5  
Canada  
Attention: Ted Zavitz

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



*Marin Banu*

**Issued by:** Marin Banu, P. Eng.

## **PRODUCTS**

**CLASS 3211 07** - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

**CLASS 3211 87** - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus -  
Certified to US Standards

CSA Enclosure Type 4X and IP65

Non-metallic enclosures, Models DIABOX and MULTIBOX, rated as Enclosure Type 4X and IP65;  
Watertight / Corrosion Resistant.

## **APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No. 0-10 - General Requirements ☐ Canadian Electrical Code, Part II

CAN/CSA Standard C22.2 No. 94.1-07 - Enclosures for Electrical Equipment, Non-Environmental  
Considerations



**Certificate:** 2474731 (LR 43674)

**Master Contract:** 157607

**Project:** 2474731

**Date Issued:** September 28, 2012

---

- CAN/CSA Standard C22.2 No. 94.2-07 - Enclosures for Electrical Equipment, Environmental Considerations
- CAN/CSA-C22.2 No. 60529:05 - Degrees of protection provided by enclosures (IP Code)
- ANSI/UL Standard 50 - Enclosures for Electrical Equipment, Non-Environmental Considerations
- ANSI/UL Standard 50E - Enclosures for Electrical Equipment, Environmental Considerations
- ANSI/IEC 60529:2004 - Degrees of protection provided by enclosures (IP Code)